

STATEMENT ACCOMPANYING FORM -A

1. Door Number of Building : Survey No. 511/2
2. Local(Street number,ward number : Sri.S.C.AgarwalRt 95
Municipality / Panchayat union /
Township / Catonment Vivekananda Vidyashram School
JaminEndathur Village, Madhurantakam Taluk,
Chengalpattu District - **603311**
3. Year of Construction : 2020 (Ground floor only)
4. Approximate cost of construction : Rs. 200.00 Lakhs (Approx)
as per current rates
5. Purpose for which the building is being : Educational Purpose
used or proposed to be used .
6. Purpose for which the building has : Educational Purpose
either to be used
7. Details of construction of the building : Medium Gravel
Particulars of the foundation soil ,
specifications of the various parts under
- a) Foundation : RCC COLUMN & FOOTING
- b) Basement : R.C.C Column with Plinth beam
- c) Superstructure : Brick Work with C.M 1:5
- d) Floor & Roof : Tiles flooring /RCC Roof
8. Period for which license is required : **14.06.2024 to 13.06.2027 (3 Yrs)**
9. Number of persons to accommodated : 500 , Persons (Approx)

Certified that no addition or alteration has been made to the existing or portion of a building for which this application has been made .I undertake to option a fresh license in case of any addition or alteration is made to the existing building or portion of building .I also undertake to obtain a fresh license if the purpose for which the license was granted for the used of the building or a portion of the building is changed or altered subsequently.

Date : 14.06.2024
Place : Chengalpattu .

Signature Of Owner of the Building


Er. S.UDHAYAKUMAR, B.E.,M.Tech (Struct)
Reg. Structural Eng. DTCP - CGLRGN/SE/GR - 1/2019/05/003
No: 20, 4th Cross Street, Anna Nagar, Chengalpattu,
E-Mail : anjuconstructions05@gmail.com. Mob : 9443101912

Engineer

FORM - B

(Form of Certificate of structural soundness under Sub-section(4) of the Tamil Nadu public buildings (licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred it is rule 4 of the Tamil Nadu public building (License) rules 1966)

(1)	Foundation		
	(i)	Depth below ground level	3 M
	(ii)	Nature of soil met with at Foundation level	Gravel
	(iii)	Pressure of foundation	15 t/m ²
	(iv)	Probable safe bearing capacity of the Strata met with at foundation	15 t/m ²
2	Superstructure		
	(i)	Maximum Stress in the most critical section masonry and concrete	Masonry 3 N/mm ² , Concrete 5.5 N/mm ² ,
	(ii)	Nature of masonry and concrete and its safe permissible stress	Masonry 4.5 N/mm ² , Concrete 7 N/mm ² ,

It is stated that the Building will be designed for Seismic forces and other loads as per the relevant Indian Standard codes.

The Structural soundness of the building has been verified by me with references to IS loading standards 875 (Latest version) and other relevant Indian Standard Code or practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.

A license may be granted for the period **14-06-2024 TO 13-06-2027- Three years.**

Place: **Chengalpattu**

Date: 14/06/2024

Signature of Engineer

Er. S.UDHAYAKUMAR, B.E.,M.Tech (Struct)
Reg. Structural Eng. DTCP - CGLRGN/SE/GR - 1/2019/05/003
No: 20, 4th Cross Street, Anna Nagar, Chengalpattu,
E-Mail : anjuconstructions05@gmail.com. Mob : 9443101912

FORM C

(Form of certificate of structural soundness under sub section (4) of section 4 of the Madras Public Buildings (Licensing Act 1965 (Madras Act of 13 of 1965) referred to in rule 4 of the Madras Public Buildings (Licensing) Rules, 1966

I certify that I have inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public buildings or the purpose noted in the statement. The structural soundness of the buildings has been verified taking into account the loading as per the latest Indian Standards 875, a license may be granted for the period **14.06.2024 to 13.06.2027**, **(Three Years)**


Er. S.UDHAYAKUMAR, B.E., M.Tech (Struct)
Reg. Structural Eng. DTCP - CGLRGN/SE/GR - 1/2019/05/003
No: 20, 4th Cross Street, Anna Nagar, Chengalpattu,
E-Mail : anjuconstructions05@gmail.com. Mob : 9443101912

Dated : 14.06.2024

Signature of Engineer

STATEMENT ACCOMPANYING THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Buildings(D.no st, place of the town)	Age of the Building	Purpose for which the Building is certified	The period for which the Structurally sound	No of persons to be accommodated	Remarks
Sri.S.C.Agarwal RT 95 Vivekananda Vidyashram School, S.NO. 511/2, JaminEndathur Village, Madhurantakam Taluk, Chengalpattu District	4 years	Educational Purpose	14.06.2024 to 13.06.2027 Three Years	500 Person (Approx)	Building is safe & strong

Dated : 14.06.2024
Place : Chengalpattu

Signature of Engineer


Er. S.UDHAYAKUMAR, B.E., M.Tech (Struct)
Reg. Structural Eng. DTCP - CGLRGN/SE/GR - 1/2019/05/003
No: 20, 4th Cross Street, Anna Nagar, Chengalpattu,
E-Mail : anjuconstructions05@gmail.com. Mob : 9443101912